

Certificate

Product certificate
K-0214145-4

kiwa

Valid from **2026-02-15** Replaces **K-0214145-3**
Page **1 of 2**

Drinking water system components – health effects according to NSF/ANSI/CAN 61

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the product

PE Fittings

supplied by

Plastitalia S.p.A

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline K15007 for “drinking water system components – health effects according to **NSF/ANSI/CAN 61**”, dated *01 February 2026*.



W. van Loon
Managing Director Nederland

Publication of this certificate is allowed.
Advice: consult www.kiwa.com in order to ensure that this certificate is still valid.



Kiwa Nederland B.V.
Sir Winston Churchillaan 273
P.O. Box 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
NL.Kiwa.Info@kiwa.com
www.kiwa.com

Certificate holder
Plastitalia S.p.A
Via Ferrara,
98061 Brolo ME
Italy
Tel. +39 0941 536311
WA. +39 3316961513
e-mail: info@plastitaliaspa.com
www.plastitaliaspa.com

K-0214145-4

Drinking water system components – health effects according to NSF/ANSI/CAN 61

Product specification

The product mentioned below belongs to this certificate.

Product	Nominal diameter (internal)	Water Contact Temp	Water Contact Material
Spigot end fittings, electrofusion socket fittings and electrofusion saddle fittings [1]	20-1600 mm [¾ -63 in]	Cold water [2]	PE
[1] Intended to be used for the transport of drinking water			
[2] For intended use in continuous exposure to cold water with a maximum end-use temperature of 23 ± 2 °C (73 ± 4 °F).			

Hygienic aspects

Approval:

This product is approved on the basis of the requirements set in NSF/ANSI/CAN 61.

Kiwa NSF/ANSI/CAN 61 criteria:

The product certification is based on two main criteria. The product shall permanently comply with:

- the product recipe approved during the assessment procedure. The recipe is laid down for the confidentiality reasons undisclosed in the appendix to certificate K-0214145. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- specific product requirements for the hygienic aspects, laid down in the appendix to certificate K-0214145. For confidentiality reasons this appendix is not public.

Marking

The certified products shall be clearly and indelibly marked with the following indications and certification mark ¹⁾:



Or words **KIWA NSF/ANSI/CAN 61**¹⁾

¹⁾ If not possible the marking shall be on the smallest packaging

Mandatory marks:

- “Suppliers name or logo”
- “Product identification (trade name or product type)”
- “Production code”
- “K-0214145”

Recommendations for the customers

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Plastitalia S.p.A.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier’s processing guidelines for the proper storage and transport methods.